
PPS Preventive Maintenance Procedure: ESA

This document has been approved by:

Paul Miller, ADSO

Date

Tom Porter, Controls Section Leader

Date

Patrick Bong, PPS Group Leader

Date

Revision 0

First edition.

Revision 1

Updated procedure from field markups.

1: Introduction

1.1 Purpose

The purpose of this preventive maintenance procedure is to verify that Personnel Protection Systems (PPS) safety devices for ESA are adequately maintained to ensure continued safe and satisfactory operation.

1.2 Scope

This document certifies that the status and control devices for ESA have been inspected and maintained.

2: Applicability

2.0.1 The preventive maintenance procedure should be completed preventiveduring major downtimes.

2.0.2 The Controls Department, PPS Group, is responsible for completing the preventive maintenance procedure.

3: Prerequisite Actions

**Initial Items
Tested**

3.0.1 Verify in the RSWCF Logbook, located in MCC (B005), that all bypasses for ESA have been removed. (If not, proceed to the next step.)

3.0.2 If all bypasses have NOT been removed, an authorized person should verify that they do not invalidate the outcome of the procedure and note them here:

3.0.3 The maintenance person will need the following tools:

- Flashlight
- Screw driver
- Voltmeter
- Door knobset tool
- Lubricants
- Cleaning fluid

4: AN1 Outer Door Check

4.1 E/E Knob Set

**Maintenance
Complete**

4.1.1 Inspect, clean and lubricate knob set. _____

4.1.2 Inspect knob set trip switches for proper adjustment. _____

4.1.3 Operate the crash bar from inside the Outer Door and verify proper operation. _____

4.1.4 Operate the knob set from outside the Outer Door and verify proper operation. _____

4.2 Door Limit Switches

**Maintenance
Complete**

4.2.1 Inspect and adjust (if necessary) the door limit switches (located on top of the door frame). _____

4.2.2 Inspect the lever arms (possibly bent or loose). _____

4.2.3 Check for loose wiring (termination points and strain relief). _____

4.3 AN1 Door

**Maintenance
Complete**

4.3.1 Lubricate the door hinges. _____

4.3.2 Inspect the door to ensure correct alignment and closure. _____

5: AN1 Inner Gate Check

5.1 Inner Gate Limit Switches

**Maintenance
Complete**

5.1.1 Inspect and adjust (if necessary) the door limit switches. _____

5.1.2 Inspect the lever arms (possibly bent or loose). _____

5.1.3 Check for loose wiring (termination points and strain relief). _____

5.2 AN1 Inner Gate

**Maintenance
Complete**

5.2.1 Lubricate the door hinges. _____

5.2.2 Inspect the door to ensure correct alignment and closure. _____

5.3 ESA Emergency Beam Shutoff Button Checks

5.3.1 Complete the following table:

Action	E/O #1 SW	E/O #2 NW	E/O #3 SE	E/O #4 NE
1. Verify that the pilot lights on the Emergency Off box are lit.	_____	_____	_____	_____
2. Verify that the Emergency Beam Shutoff sign is in place.	_____	_____	_____	_____
3. Verify that the button action is smooth.	_____	_____	_____	_____
4. Open the button box cover, place a voltmeter across the contact blocks, operate the switch and verify that it is operating correctly.	_____	_____	_____	_____
5. Check the wiring termination points for shorts, loose connections and proper strain relief.	_____	_____	_____	_____
6. Inspect contact block for radiation damage, loose connections or corrosion.	_____	_____	_____	_____

6: Big Door Check

6.1 Door Limit Switches

**Maintenance
Complete**

6.1.1 Inspect and adjust (if necessary) the door limit switches (located on the side of the door frame towards AN4). _____

6.1.2 Inspect the lever arms (possibly bent or loose). _____

7: AN3 Outer Door Check

7.1 Knob Set

**Maintenance
Complete**

7.1.1 Inspect, clean and lubricate knob set. _____

7.1.2 Inspect knob set trip switches for proper adjustment. _____

7.1.3 Operate the knob set from inside the Outer Door and verify proper operation. _____

7.1.4 Operate the knob set from outside the Outer Door and verify proper operation. _____

7.1.5 Set ESA to **CONTROLLED ACCESS**, release a keybank key, and obtain a door release. Check the electric strike for proper operation. _____

7.1.6 Inspect annunciator panel lamps for proper operation. _____

7.2 Door Limit Switches

**Maintenance
Complete**

7.2.1 Inspect and adjust (if necessary) the door limit switches (located on top of the door frame). _____

7.2.2 Inspect the lever arms (possibly bent or loose). _____

7.2.3 Check for loose wiring (termination points and strain relief). _____

7.3 AN3 Door

**Maintenance
Complete**

7.3.1 Lubricate the door hinges. _____

7.3.2 Inspect the door to ensure correct alignment and closure. _____

8: AN3 Keybank Check

**Maintenance
Complete**

8.0.1 Inspect the lockout cam pin hub for alignment and tightness. _____

8.0.2 Inspect the keysense pin hub for alignment and tightness. _____

8.0.3 Clean, adjust and lubricate the keybank. _____

8.0.4 Check the wiring termination points for shorts and loose connections. _____

8.0.5 Inspect all keys for cracks and bends. _____

8.0.6 Inspect the microswitches for correct adjustment. _____

8.0.7 Verify that the Emergency Key Release break-away glass and hammer are in place. _____

8.0.8 Set ESA to **CONTROLLED ACCESS** and verify the proper functioning of the keybank. _____

8.0.9 Check the key release for each keybank key. _____

9: AN3 Inner Gate Check

9.1 Inner Gate Limit Switches **Maintenance Complete**

9.1.1 Inspect and adjust (if necessary) the door limit switches. _____

9.1.2 Inspect the lever arms (possibly bent or loose). _____

9.1.3 Check for loose wiring (termination points and strain relief). _____

9.2 AN3 Inner Gate **Maintenance Complete**

9.2.1 Lubricate the door hinges. _____

9.2.2 Inspect the door to ensure correct alignment and closure. _____

10: AN4 Outer Door Check

10.1 E/E Knob Set

**Maintenance
Complete**

10.1.1 Inspect, clean and lubricate knob set. _____

10.1.2 Inspect knob set trip switches for proper adjustment. _____

10.1.3 Operate the knob set from inside the Outer Door and verify proper operation. _____

10.1.4 Operate the knob set from outside the Outer Door and verify proper operation. _____

10.1.5 Set ESA to **CONTROLLED ACCESS**, release a keybank key, and obtain a door release. Check the electric strike for proper operation. _____

10.2 Door Limit Switches

**Maintenance
Complete**

10.2.1 Inspect and adjust (if necessary) the door limit switches (located on top of the door frame). _____

10.2.2 Inspect the lever arms (possibly bent or loose). _____

10.2.3 Check for loose wiring (termination points and strain relief). _____

10.3 AN4 Door

**Maintenance
Complete**

10.3.1 Lubricate the door hinges. _____

10.3.2 Inspect the door to ensure correct alignment and closure. _____

11: AN4 Keybank Check

Maintenance
Complete

- 11.0.1 Inspect the lockout cam pin hub for alignment and tightness. _____
- 11.0.2 Inspect the keysense pin hub for alignment and tightness. _____
- 11.0.3 Clean, adjust and lubricate the keybank. _____
- 11.0.4 Check the wiring termination points for shorts and loose connections. _____
- 11.0.5 Inspect all keys for cracks and bends. _____
- 11.0.6 Inspect the microswitches for correct adjustment. _____
- 11.0.7 Verify that the Emergency Key Release break-away glass and hammer are in place. _____
- 11.0.8 Set ESA to **CONTROLLED ACCESS** and verify the proper functioning of the keybank. _____
- 11.0.9 Check the key release for each keybank key. _____

12: AN4 Inner Gate Check

12.1 Inner Gate Limit Switches

**Maintenance
Complete**

12.1.1 Inspect and adjust (if necessary) the door limit switches. _____

12.1.2 Inspect the lever arms (possibly bent or loose). _____

12.1.3 Check for loose wiring (termination points and strain relief). _____

12.2 AN4 Inner Gate

**Maintenance
Complete**

12.2.1 Lubricate the door hinges. _____

12.2.2 Inspect the door to ensure correct alignment and closure. _____

13: Beam Dump East Door Check

13.1 Door Limit Switches

**Maintenance
Complete**

13.1.1 Inspect and adjust (if necessary) the door limit switches (located on top of the door frame). _____

13.1.2 Inspect the lever arms (possibly bent or loose). _____

13.1.3 Check for loose wiring (termination points and strain relief). _____

13.2 Beam Dump East Door**Maintenance
Complete**

13.2.1 Lubricate the door hinges. _____

13.2.2 Inspect the door to ensure correct alignment and closure. _____

13.2.3 Inspect annunciator panel lamps for proper operation. _____

13.3 BDE Emergency Beam Shutoff Button Checks

13.3.1 Complete the following table:

Action	E/O #1
1. Verify that the pilot lights on the Emergency Off box are lit.	_____
2. Verify that the Emergency Beam Shutoff sign is in place.	_____
3. Verify that the button action is smooth.	_____
4. Open the button box cover, place a voltmeter across the contact blocks, operate the switch and verify that it is operating correctly.	_____
5. Check the wiring termination points for shorts, loose connections and proper strain relief.	_____
6. Inspect contact block for radiation damage, loose connections or corrosion.	_____

14: West Trench Check

14.1 South Door Hardware

**Maintenance
Complete**

14.1.1 Clean and lubricate the door knobset.

14.1.2 Lubricate the door hinges.

14.1.3 Check the door for proper alignment and closure.

14.1.4 Inspect door release LED for proper operation.

14.1.5 Inspect annunciator panel for proper operation.

14.2 South Door Limit Switches

**Maintenance
Complete**

14.2.1 Inspect and adjust (if necessary) the door limit switches.

14.2.2 Inspect the lever arms (possibly bent or loose).

14.2.3 Check for loose wiring (termination points and strain relief).

14.3 West Trench Emergency Beam Shutoff Pull Cord

14.3.1 Check the pull cord for proper operation.

14.4 North Door Hardware

**Maintenance
Complete**

14.4.1 Clean and lubricate the door knobset.

14.4.2 Lubricate the door hinges.

14.4.3 Check the door for proper alignment and closure.

14.5 North Door Limit Switches

**Maintenance
Complete**

14.5.1 Inspect and adjust (if necessary) the door limit switches.

14.5.2 Inspect the lever arms (possibly bent or loose).

14.5.3 Check for loose wiring (termination points and strain relief).

15: Central Trench Check

15.1 South Door Hardware

**Maintenance
Complete**

15.1.1 Clean and lubricate the door knobset.

15.1.2 Lubricate the door hinges.

15.1.3 Check the door for proper alignment and closure.

15.1.4 Inspect door release LED for proper operation.

15.1.5 Inspect annunciator panel for proper operation.

15.2 South Door Limit Switches

**Maintenance
Complete**

15.2.1 Inspect and adjust (if necessary) the door limit switches.

15.2.2 Inspect the lever arms (possibly bent or loose).

15.2.3 Check for loose wiring (termination points and strain relief).

15.3 Central Trench Emergency Beam Shutoff

15.3.1 Check the pull cord for proper operation.

15.4 North Door Hardware

**Maintenance
Complete**

15.4.1 Clean and lubricate the door knobset.

15.4.2 Lubricate the door hinges.

15.4.3 Check the door for proper alignment and closure.

15.5 North Door Limit Switches

**Maintenance
Complete**

15.5.1 Inspect and adjust (if necessary) the door limit switches.

15.5.2 Inspect the lever arms (possibly bent or loose).

15.5.3 Check for loose wiring (termination points and strain relief).

16: East Trench Check

16.1 South Door Hardware

**Maintenance
Complete**

16.1.1 Clean and lubricate the door knobset.

16.1.2 Lubricate the door hinges.

16.1.3 Check the door for proper alignment and closure.

16.1.4 Inspect door release LED for proper operation.

16.1.5 Inspect annunciator panel for proper operation.

16.2 South Door Limit Switches

**Maintenance
Complete**

16.2.1 Inspect and adjust (if necessary) the door limit switches.

16.2.2 Inspect the lever arms (possibly bent or loose).

16.2.3 Check for loose wiring (termination points and strain relief).

16.3 East Trench Emergency Beam Shutoff

16.3.1 Check the pull cord for proper operation.

16.4 North Door Hardware

**Maintenance
Complete**

16.4.1 Clean and lubricate the door knobset.

16.4.2 Lubricate the door hinges.

16.4.3 Check the door for proper alignment and closure.

16.5 North Door Limit Switches

**Maintenance
Complete**

16.5.1 Inspect and adjust (if necessary) the door limit switches.

16.5.2 Inspect the lever arms (possibly bent or loose).

16.5.3 Check for loose wiring (termination points and strain relief).

17.2 Controls Department Approval

Signature

Name and title (print)

Date

17.3 PPS Follow-up

The PPS Group Leader files the approved preventive maintenance procedure in the designated PPS file area.