

## SLAC Magnetic Measurement Plan and Traveler for 190A Unipolar LCLS-II Quadrupoles of Type 2Q4W (SA-344-112-18)

This traveler is intended to cover mechanical fiducialization and magnetic measurements of the 2Q4W quadrupole magnets needed for LCLS-II. There are a total of 6 of these magnets needed for the LCLS-II. There are 3 different configurations for this magnet, SA-344-112-18, SA-344-112-08, and SA-344-112-15. The table below gives the MAD names, polarities, and installation directions of the 190 A unipolar 2Q4W quadrupoles.

MAD Name	Eng. Name	Drawing#	Barcode	Polarity	Bus bars
QBP30	2Q4W	SA-344-112-18	4231	QD	downstream
QBP31	2Q4W	SA-344-112-18	4234	QF	downstream
QBP32	2Q4W	SA-344-112-18	4236	QD	upstream
QBP33	2Q4W	SA-344-112-18		QD	downstream
QBP34	2Q4W	SA-344-112-18		QF	downstream
QBP36	2Q4W	SA-344-112-18		QF	downstream

### Receiving:

The following information is to be noted upon receipt of the magnets by the SLAC MM group:

Received by (MMG initials):	SDA
Date received (dd-mm-yyyy):	2/19/2019
SLAC barcode number:	4234
Vendor serial number on the magnet:	8

### Preparation:

A beam direction arrow, with text “beam direction”, is to be applied to the top and/or connector side of the magnet with a sticker supplied by LCLS-II (T. Smith will determine the direction).

Beam-direction arrow in place (initials):	SDA
---	-----

**Fiducialization:**

Fiducialization may be done before or after magnetic measurements. The magnet is to be fiducialized by the CMM group. This will require the installation of removable tooling balls, location of the geometric axis of the poles of the magnet, and location of tooling balls with respect to the center of this geometric axis when the poles are aligned precisely horizontal.

CMM technician (initials):	KC
----------------------------	----

URL of on-line CMM fiducialization data (please modify or correct if necessary):


<a href="http://www-group.slac.stanford.edu/met/MagMeas/MAGDATA/LCLS-II/Fiducial%20Reports4234/_Fiducial_Report.pdf">http://www-group.slac.stanford.edu/met/MagMeas/MAGDATA/LCLS-II/Fiducial%20Reports4234/_Fiducial_Report.pdf</a>
---

**Magnetic Measurements:**

Enter URL of on-line magnetic measurements data (please modify or correct if necessary):

<a href="http://www-group.slac.stanford.edu/met/MagMeas/MAGDATA/LCLS-II/Quad/4234">http://www-group.slac.stanford.edu/met/MagMeas/MAGDATA/LCLS-II/Quad/4234</a>
---

- 1) Determine the connection polarity (with main supply outputting positive current) which produces a “positive” field polarity and “negative” field polarity as shown below:



**Figure 1.** Polarity convention for magnets having “positive” (left) and “negative” (right) polarities.

- 2) Mark the polarity near the magnet leads with clear “+” and “-” labels as shown above.

Magnet polarity chosen from Fig. 1 is (P or N):	P
---	---

- 3) Connect the magnet to the LCW supply. The total magnet flow should be 0.8 gpm. Record the  $\Delta P$  and flow below.

Record total flow rate and pressure.	0.8 gpm @114 psi
--------------------------------------	------------------

- 4) Connect the magnet terminals in the correct polarity as established above, to a unipolar power supply with maximum current  $I \geq 190$  A.
- 5) Run the magnet up to 190 A for ~30 minutes to warm it up (record temperature).

LCW delta T ( $^{\circ}\text{C}$ )	7.0 $^{\circ}\text{C}$
Ambient temperature ( $^{\circ}\text{C}$ ):	18.5 $^{\circ}\text{C}$
Final magnet steel temperature ( $^{\circ}\text{C}$ ):	27.0 $^{\circ}\text{C}$

- 6) Standardize the magnet, starting from zero to 190 A and back to zero, through three full cycles, finally ending at zero, with a flat-top pause time (at both 0 and 190 A) of 10 seconds. Use a three liner ramp rate of 20 A/sec, if possible, and record the ramp rate used.

Standardization complete (initials):	SDA
Ramp rate used (A/sec):	20 A/sec

- 7) If the power supply can be run as low as 2 A with  $<10$ -mA (0.5%) rms current regulation, then measure  $\int Gdl$  from 0 to 190 A following the current range step sizes given in the table below.

Current Range	Step Size Up	Step Size Down
0 to 20 A	4-A	4-A
20 to 170 A	10-A	20-A
170 to 190 A	5-A	20-A

Filename & run number of $\int Gdl$ up & down data:	Strdat.ru1, strplt.ru1
---	------------------------

- 8) For all magnets, with rotating coil, measure the magnet harmonics at 20, 100, 190 A current setting. Multipole values should be given as a percentage of the quadrupole moment evaluated at the probe radius.

Filename & run number of harmonic data:	Hardat.ru1, harplt.ru1
Probe radius used for harmonics (cm):	1.95965

Rotating Coil Designation (Name)	48BC1.6
----------------------------------	---------

9) Confirm the pole-tip field using a Hall probe at an excitation current of 190 A.

Hall probe pole-tip field at 190 A (mean of 4 poles):	0.579 +/- 0.01 T @ 190.0074 A
---	-------------------------------

10) For one magnet only, perform a final thermal test. Run the current up to 190 A. Measure the magnet temperature after it stabilizes (2-4 hours?). Record the temperature below.

LCW delta T (°C)	Measurement made on 4236
Ambient temperature (°C):	Measurement made on 4236
Final magnet steel temperature (°C):	Measurement made on 4236

11) Measure the inductance and resistance of the magnet:

Inductance of coil (mH):	2.112 mH
Resistance of coil (Ohms):	0.0679 Ohm
Magnet temperature in degrees C	25.1 °C

12) Upon completion of tests, email URL of on-line data to Mark Woodley. Mark Woodley will determine if the magnet is accepted. Upon acceptance of magnet, analysis data will be placed in on-line data folder.

Magnet accepted and Analysis file(s) put into on-line data folder (initials):	SDA
Assigned beamline location (MAD-deck name):	<b>QBP31</b>