

SLAC National Accelerator Laboratory

Structural Calculation


Delta Undulator Anchor Bolt Design

Location: B081


By: Felix K. Adikara



April 9, 2014



5/8 DIA. HILTI KB-T2, SS
WITH 4" EMBED, TYP AT 4 LOC.



ANCHOR BOLT DETAIL
HTS

ESTIMATED MASS
600 LBS

CHECK-PRINT
nikosov
03-25-2014 04:47:09 PM

SCALE: 1:20

DATE	DESCRIPTION	BY	APP'D
03/25/2014	FIELD MAPPING TEST INSTALL	nikosov	
03/25/2014	DELTA MECHANICAL SYSTEMS		
03/25/2014	UNDULATOR		
03/25/2014	MMIF COVER		
03/25/2014	CONCRETE TUB		
03/25/2014	ANCHOR BOLT		
03/25/2014	FIELD MAPPING TEST INSTALL		

DATE	DESCRIPTION	BY	APP'D
03/25/2014	FIELD MAPPING TEST INSTALL	nikosov	
03/25/2014	DELTA MECHANICAL SYSTEMS		
03/25/2014	UNDULATOR		
03/25/2014	MMIF COVER		
03/25/2014	CONCRETE TUB		
03/25/2014	ANCHOR BOLT		
03/25/2014	FIELD MAPPING TEST INSTALL		

SCALE: 1:20

SLAC ENERGY

DELTA MECHANICAL SYSTEMS
FIELD MAPPING TEST INSTALL

DATE: 03/25/2014
TIME: 04:47:09 PM

PROJECT: SLAC ENERGY
DRAWING: DELTA MECHANICAL SYSTEMS
FIELD MAPPING TEST INSTALL
SCALE: 1:20

DATE: 03/25/2014
TIME: 04:47:09 PM

PROJECT: SLAC ENERGY
DRAWING: DELTA MECHANICAL SYSTEMS
FIELD MAPPING TEST INSTALL
SCALE: 1:20

DATE: 03/25/2014
TIME: 04:47:09 PM

PROJECT: SLAC ENERGY
DRAWING: DELTA MECHANICAL SYSTEMS
FIELD MAPPING TEST INSTALL
SCALE: 1:20

Project: To calculate the anchor bolt requirement for the delta undulator

Location: B081 First Floor

Note: Undulator is not part of this calculation

- Reference:**
1. 2013 California Building Code
 2. ASCE 7-10 Minimum Design Loads for Buildings and Other Structures
 3. AISC ninth edition
 4. Drawings: SLAC: ID-381-920-06-C0
 5. ESR - 1917 dated 5/1/2013 for HILTI Kwik Bolt TZ
 6. SLAC-I-720-0A24E-001-R004D: Seismic Design Specification for Buildings, Structures, Equipment and Systems: 2014
Rev. 4D has not been issued at this time, but calculation is conservative relative to Rev. 3

Governing code:

Ref. 2 - Chapter 13: Seismic design requirements for non-structural component that are permanently attached to structure.
Paragraph 13.3: Seismic demands on non-structural component

Input Data: Occupancy category II (Ref. 1 Table 1-1)

Weight of undulator =	3900 lbs	Provided by user
Weight of pipe support (16" dia. Std. 3 feet ea)=	376 lbs	
Weight of top and bott plates (18"x18"x 1/2") =	92 lbs	
Weight of equipment + pipe stand +plates =	4367 lbs	
Height of equipment =	44.00 inch	Ref. 4
Dist. betw cg of equip. and top of floor h =	43.50 inch	Ref. 4
Distance between post d =	15.00 inch	Field measurement

Ip =	1	Importance factor	Ref. 2 Table 11.5-1 for occupancy category II
Rp =	2.5	Response modification factor	Ref. 2 Table 13.5-1 for laboratory equipment
ap =	1	Component amplification factor	Ref. 2 Table 13.5-1 for laboratory equipment

Seismic Ground Motion Value: Location 13 (max. value) Ref. 6

Soil classification: D

Ss =	3.001 g	MCE spectral acceleration at short period
S1 =	1.198 g	MCE spectral acceleration at one period
SDs =	2.000 g	Design spectral acceleration at short period
SD1 =	1.198 g	Design spectral acceleration at one second

Base shear:

The horizontal seismic design force F_p : $z =$ 0 ft (height in structure of point of attachment, $z = 0$ for first floor)
 $H =$ 20 ft (height of roof)

$$F_p = [(0.4 \times a_p \times S_Ds \times W_p) / (R_p / I_p)] \times (1 + 2 z/H) = 1398 \text{ lbs} \quad \text{Ref.2 Eq. 13.3-1}$$

$$F_p \text{ max} = 1.6 \times S_Ds \times I_p \times W_p = 13976 \text{ lbs} \quad \text{Ref.2 Eq. 13.3-2}$$

$$F_p \text{ min} = 0.3 \times S_Ds \times I_p \times W_p = 2620 \text{ lbs Control } 0.60 W_p \quad \text{Ref.2 Eq. 13.3-3}$$

1. Anchor Bolt:

Strength Design load combination: $0.5 D + 1.0 E$ Ref.2 Section 12.4.2.3
Ref. 2 Section 13.3.1

Applied load to the base plate:	$f_v = F_p / 2 =$	1310 lbs
	$M_o = (1.0 E \times h) / 2 =$	56996 in.lbs
	$DL = (0.5 \times DL)$	-2184 lbs

4 - HILTI KB-TZ, SS 5/8" diameter with 4" embedment per leg is adequate

2. Pipe 16" std. pipe:

Allow. Stress Design: $1.3 D + 0.7 E$ Ref.2 Section 12.4.2.3
and Ref. 2 Section 13.3.1

Area $A =$	18.4 inch ²	$S =$	70.30 inch ³
$M = (0.7 \times F_p \times 0.5) \times (h) =$			39897 inch. lbs
Axial load $P_a = 0.5 \times 1.3 \times DL =$			2839 lbs
Shear load $f_v = 0.5 \times 0.7 \times F_p =$			917 lbs
Yield Strength F_y for SS 304 =			30000 psi
$f_a = P_a / A =$	154 psi	<	$F_a =$ 18000 psi OK
$f_b = M / S =$	568 psi	<	$F_b =$ 18000 psi OK
$f_v = f_v / A =$	50 psi	<	$F_b =$ 12000 psi OK

Pipe 16" std. pipe is acceptable

Note: Stress is very low, therefore weld between base plate and pipe is OK
Axial load is small, therefore local stress/punching shear on exist. Slab is OK



Figure 2 SLAC Map

Table 2 Seismic Ground Motion Values

Location	S_s	S_1	$S_{0.5}$	$S_{0.1}$	SDC R.C. I/II	SDC R.C. III	SDC R.C. IV
1	2.166	0.0917	1.444	0.917	E	E	F
2	2.170	0.923	1.447	0.923	E	E	F
3	2.267	0.952	1.512	0.952	E	E	F
4	2.358	0.977	1.572	0.977	E	E	F
5	2.563	1.014	1.709	1.014	E	E	F
6	2.403	0.973	1.602	0.973	E	E	F
7	2.483	0.991	1.655	0.991	E	E	F
8	2.613	1.022	1.742	1.022	E	E	F
9	2.745	1.055	1.830	1.055	E	E	F
10	2.840	1.094	1.893	1.094	E	E	F
11	2.897	1.132	1.931	1.132	E	E	F
12	2.946	1.164	1.964	1.164	E	E	F
13	3.001	1.198	2.000	1.198	E	E	F
14	2.315	0.958	1.543	0.958	E	E	F

*The SDS values are based on site class D

www.hilti.us


Company: SLAC National Accelerator Laboratory
Specifier: Felix K. Adikara
Address: 2575 Sand Hill Road, Menlo Park, CA 94025
Phone | Fax: |
E-Mail: |

Page:
Project:
Sub-Project | Pos. No.:
Date:

1
Delta Undulator
B081 First Floor
4/9/2014

Specifier's comments:**1 Input data**

Anchor type and diameter:	Kwik Bolt TZ - SS 304 5/8 (4)
Effective embedment depth:	$h_{ef} = 4.000$ in., $h_{nom} = 4.438$ in.
Material:	AISI 304
Evaluation Service Report:	ESR-1917
Issued Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318 / AC193
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.
Anchor plate:	$l_x \times l_y \times t = 18.000$ in. \times 18.000 in. \times 0.500 in.; (Recommended plate thickness: not calculated)
Profile:	S shape (AISC); (L x W x T x FT) = 3.000 in. \times 2.330 in. \times 0.170 in. \times 0.260 in.
Base material:	cracked concrete, 3000, $f'_c = 3000$ psi; $h = 6.000$ in.
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar yes (D.3.3.6)
Seismic loads (cat. C, D, E, or F)	yes (D.3.3.6)

**Geometry [in.] & Loading [lb, in.lb]**

www.hilti.us

Company: SLAC National Accelerator Laboratory
 Specifier: Felix K. Adikara
 Address: 2575 Sand Hill Road, Menlo Park, CA 94025
 Phone | Fax: |
 E-Mail: |

Page: 2
 Project: Delta Undulator
 Sub-Project | Pos. No.: B081 First Floor
 Date: 4/9/2014

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	1283	338	0	338
2	1283	338	0	338
3	0	338	0	338
4	0	338	0	338

max. concrete compressive strain: 0.05 [%]
 max. concrete compressive stress: 211 [psi]
 resulting tension force in (x/y)=(0.000/-7.500): 2565 [lb]
 resulting compression force in (x/y)=(0.000/8.169): 4745 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_n = N_{ua}/\phi N_n$	Status
Steel Strength*	1283	13972	10	OK
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Strength**	2565	5084	51	OK

* anchor having the highest loading **anchor group (anchors in tension)

3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-1917
 $\phi N_{steel} \geq N_{ua}$ ACI 318-08 Eq. (D-1)

Variables

n	$A_{se,N}$ [in. ²]	f_{uta} [psi]
1	0.16	115000

Calculations

N_{sa} [lb]	18630
---------------	-------

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
18630	0.750	13972	1283

www.hilti.us

Company: SLAC National Accelerator Laboratory
 Specifier: Felix K. Adikara
 Address: 2575 Sand Hill Road, Menlo Park, CA 94025
 Phone | Fax: |
 E-Mail: |

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

3
 Delta Undulator
 8081 First Floor
 4/9/2014

3.2 Concrete Breakout Strength

$$N_{cbg} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-08 Eq. (D-5)}$$

$$\phi N_{cbg} \geq N_{ua} \quad \text{ACI 318-08 Eq. (D-1)}$$

$$A_{Nc} \text{ see ACI 318-08, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-08 Eq. (D-6)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-9)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-11)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-13)}$$

$$N_b = k_c \lambda \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-08 Eq. (D-7)}$$

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
4.000	0.000	0.000	8.000	1.000
c_{ac} [in.]	k_c	λ	f'_c [psi]	
8.875	17	1	3000	

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
288.00	144.00	1.000	1.000	1.000	1.000	7449

Results

N_{cbg} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	ϕN_{cbg} [lb]	N_{ua} [lb]
14898	0.650	0.750	0.700	5084	2565

www.hilti.us

 Company: SLAC National Accelerator Laboratory
 Specifier: Felix K. Adikara
 Address: 2575 Sand Hill Road, Menlo Park, CA 94025
 Phone | Fax: |
 E-Mail: |

 Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

 4
 Delta Undulator
 B081 First Floor
 4/9/2014

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_v = V_{ua}/\phi V_n$	Status
Steel Strength*	338	6078	6	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength**	1350	21900	7	OK
Concrete edge failure in direction y+**	1350	3337	41	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

 $V_{sa,eq}$ = ESR value refer to ICC-ES ESR-1917
 $\phi V_{steel} \geq V_{ua}$ ACI 318-08 Eq. (D-2)

Variables

n	$A_{se,V}$ [in. ²]	f_{ua} [psi]
1	0.16	115000

Calculations

V_{sa} [lb]
9350

Results

V_{sa} [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
9350	0.650	6078	338

4.2 Pryout Strength

$$V_{cp,g} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-08 Eq. (D-31)}$$

$$\phi V_{cp,g} \geq V_{ua} \quad \text{ACI 318-08 Eq. (D-2)}$$

$$A_{Nc} \text{ see ACI 318-08, Part D.5.2.1, Fig. RD.5.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-08 Eq. (D-6)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-9)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{C_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-11)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{1.5 h_{ef}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-13)}$$

$$N_b = k_c \lambda \sqrt{f_c} h_{ef}^{1.5} \quad \text{ACI 318-08 Eq. (D-7)}$$

Variables

k_{cp}	h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$C_{a,min}$ [in.]
2	4.000	0.000	0.000	8.000

$\psi_{c,N}$	C_{ac} [in.]	k_c	λ	f_c [psi]
1.000	8.875	17	1	3000

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
576.00	144.00	1.000	1.000	1.000	1.000	7449

Results

$V_{cp,g}$ [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	$\phi V_{cp,g}$ [lb]	V_{ua} [lb]
59592	0.700	0.750	0.700	21900	1350

www.hilti.us

Company: SLAC National Accelerator Laboratory
 Specifier: Felix K. Adikara
 Address: 2575 Sand Hill Road, Menlo Park, CA 94025
 Phone | Fax: |
 E-Mail: |

Page:
 Project:
 Sub-Project | Pos. No.:
 Date:

5
 Delta Undulator
 B081 First Floor
 4/9/2014

4.3 Concrete edge failure in direction y+

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vc0}} \right)^{\psi_{ec,V} \psi_{ed,V} \psi_{e,V} \psi_{h,V} \psi_{parallel,V}} V_b \quad \text{ACI 318-08 Eq. (D-22)}$$

$$\phi V_{cbg} \geq V_{ub} \quad \text{ACI 318-08 Eq. (D-2)}$$

$$A_{Vc} \text{ see ACI 318-08, Part D.6.2.1, Fig. RD 6.2.1(b)}$$

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-08 Eq. (D-23)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-26)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-08 Eq. (D-28)}$$

$$\psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-08 Eq. (D-29)}$$

$$V_b = \left(7 \left(\frac{l_b}{d_b} \right)^{0.2} \sqrt{d_b} \right) \lambda \sqrt{f_c} c_{a1}^{1.5} \quad \text{ACI 318-08 Eq. (D-24)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	$e_{c,v}$ [in.]	$\psi_{e,v}$	h_a [in.]
5.333	8.000	0.000	1.000	6.000

l_b [in.]	λ	d_b [in.]	f_c [psi]	$\psi_{parallel,V}$
4.000	1.000	0.625	3000	1.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\psi_{ec,V}$	$\psi_{ed,V}$	$\psi_{h,V}$	V_b [lb]
186.00	128.00	1.000	1.000	1.155	5412

Results

V_{cbg} [lb]	$\phi_{concrete}$	$\phi_{seismic}$	$\phi_{nonductile}$	ϕV_{cbg} [lb]	V_{ub} [lb]
9080	0.700	0.750	0.700	3337	1350

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.505	0.405	5/3	55	OK

$$\beta_{NV} = \beta_N + \beta_V \leq 1$$

www.hilti.us

Company: SLAC National Accelerator Laboratory
Specifier: Felix K. Adikara
Address: 2575 Sand Hill Road, Menlo Park, CA 94025
Phone | Fax: |
E-Mail: |

Page: 6
Project: Delta Undulator
Sub-Project | Pos. No.: B081 First Floor
Date: 4/9/2014

6 Warnings

- To avoid failure of the anchor plate the required thickness can be calculated in PROFIS Anchor. Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-08 Appendix D, Part D.3.3.4 that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, Part D.3.3.5 requires that the attachment that the anchor is connecting to the structure shall be designed so that the attachment will undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. In lieu of D.3.3.4 and D.3.3.5, the minimum design strength of the anchors shall be multiplied by a reduction factor per D.3.3.6.
An alternative anchor design approach to ACI 318-08, Part D.3.3 is given in IBC 2009, Section 1908.1.9. This approach contains "Exceptions" that may be applied in lieu of D.3.3 for applications involving "non-structural components" as defined in ASCE 7, Section 13.4.2.
An alternative anchor design approach to ACI 318-08, Part D.3.3 is given in IBC 2009, Section 1908.1.9. This approach contains "Exceptions" that may be applied in lieu of D.3.3 for applications involving "wall out-of-plane forces" as defined in ASCE 7, Equation 12.11-1 or Equation 12.14-10.
- It is the responsibility of the user when inputting values for brittle reduction factors ($\phi_{\text{nonductile}}$) different than those noted in ACI 318-08, Part D.3.3.6 to determine if they are consistent with the design provisions of ACI 318-08, ASCE 7 and the governing building code.
Selection of $\phi_{\text{nonductile}} = 1.0$ as a means of satisfying ACI 318-08, Part D.3.3.5 assumes the user has designed the attachment that the anchor is connecting to undergo ductile yielding at a force level \leq the design strengths calculated per ACI 318-08, Part D.3.3.3.

Fastening meets the design criteria!

www.hilti.us


Company: SLAC National Accelerator Laboratory
 Specifier: Felix K. Adikara
 Address: 2575 Sand Hill Road, Menlo Park, CA 94025
 Phone | Fax: |
 E-Mail: |

Page: 7
 Project: Delta Undulator
 Sub-Project | Pos. No.: B081 First Floor
 Date: 4/9/2014

7 Installation data

Anchor plate, steel: -
 Profile: S shape (AISC); 3.000 x 2.330 x 0.170 x 0.260 in.
 Hole diameter in the fixture: $d_f = 0.688$ in.
 Plate thickness (input): 0.500 in.
 Recommended plate thickness: not calculated
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ - SS 304, 5/8 (4)
 Installation torque: 720.001 in.lb
 Hole diameter in the base material: 0.625 in.
 Hole depth in the base material: 4.750 in.
 Minimum thickness of the base material: 6.000 in.



Coordinates Anchor in.

Anchor	x	y	C_{-x}	C_{+x}	C_{-y}	C_{+y}
1	-7.500	-7.500	8.000	23.000	8.000	23.000
2	7.500	-7.500	23.000	8.000	8.000	23.000
3	-7.500	7.500	8.000	23.000	23.000	8.000
4	7.500	7.500	23.000	8.000	23.000	8.000

www.hilti.us

Company: SLAC National Accelerator Laboratory
Specifier: Felix K. Adikara
Address: 2575 Sand Hill Road, Menlo Park, CA 94025
Phone | Fax: |
E-Mail: |

Page: 8
Project: Delta Undulator
Sub-Project | Pos. No.: B081 First Floor
Date: 4/9/2014

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Adikara, Felix K.

From: Levashov, Yurii I.
Sent: Wednesday, March 26, 2014 8:08 AM
To: Adikara, Felix K.
Subject: Anchoring DELTA undulator
Attachments: Measurement set-up.pdf

Hi Felix,

We need to anchor another undulator, called DELTA, in our lab, Bldg.81, rm.114, next to our Dover bench, see picture attached.

It is 3.2m long device, ~3900 lbs. weight. It will stay in our lab for 1 month then will be moved into LCLS tunnel.

We'll place the undulator on 2 support stands to be designed. One stand will rest on 3' thick concrete pad. Another one will be on 6" floor.

How should we secure them safely to the floor to meet all requirements? Which anchors should we use, what footprint is required for the supports?

Thanks,
Yurii Levashov
x2178

