

# Fiducials for QFC Std. Vac. Chamber

# QFC015

Date:

10/23/01

Chamber:


QFC015

Operator(s):

F. Gaudreault  
L. Griffin

Notes:

Traveler Step #1200: 08/20/01; #1280: 08/23/01 (#1380 & #1465 see below)



## Fiducial Coordinates for QFC Standard Vacuum Chamber: (inches)

Fiducial	Z	X	Y
TB1	-13.800	-3.192	4.408
TB2	-13.792	7.292	4.360
TB3	37.426	-5.214	4.427
TB4	37.541	13.294	2.955
TB5	33.437	7.567	2.059
TB6	13.388	2.636	2.372
TB7	13.435	2.635	-2.366

TB5 <sub>x</sub> Absorber Check	
Measured	7.567
Nominal	7.524
Difference	0.043

STATUS: **OK**  
< 0.100 in

Source: **Fid. Step**

**Description:**  
Fid. vals based on internal chamber datum. Source="US Step" indicates final data unless rechecked.


## Flange Positions: (inches)

Flange	Z	X	Y	Source
IN		1.852	0.012	US
OUT	40.701	1.845	0.024	DS
NIP	N/A	10.522	-0.023	DS

Source: **Fid. Step**

**Description:**  
Flange values based on scans of flange surfaces and referenced to internal chamber datum.

**Fiducialization Step: (Traveler Step # 1380: 10/19/01; 10/23/01; 11/08/01)**



QFC015

**Step 1: Fiducial and Flange Coordinates for QFC Std. Vac. Chamber**

Fiducial	Z	X	Y	Downstream Flanges	
TB1	-13.800	-3.192	4.408	OUT	NIP
TB2	-13.792	7.292	4.360	Z	41.451 N/A in
TB3	37.426	-5.214	4.427	X	1.845 10.522 in
TB4	37.541	13.294	2.955	Y	0.024 -0.023 in
TB5	33.437	7.567	2.059		
TB6	13.388	2.636	2.372		
TB7	13.435	2.635	-2.366		
	inches	inches	inches	Nominals:	Xout 1.836 Yout 0.000

**Description:**  
Fiducial values based on internal chamber datum. Flange OUT X and Y values checked  $\pm 0.020$  in.

Status

**Step 2: Downstream Flange Check**

Flange	Yaw	Pitch	Diameter		Nominal Diameter	
			Meas.	Actual		
OUT	-8.92	-1.60	11.463	9.963	9.970	OK
NIP	N/A	N/A	4.211	2.711	2.730	DIAM? ??
	mrad	mrad	inches		$\pm 0.015$ in	

**Description:**  
Yaw -6 to -13 mrad. Pitch  $\pm 3$  mrad. Diameter difference  $\pm 0.015$  in


**Step 1: Change in Fiducial Values Check**

Fiducial	Delta Z	Delta X	Delta Y
TB1			
TB2			
TB3			
TB4			
TB5			
TB6			
TB7			
	inches	inches	inches

**PENDING**  
**PENDING**  
**PENDING**  
**PENDING**  
**PENDING**  
**PENDING**  
**PENDING**  
±0.006 in

**Description:**  
Difference between current and previous fiducial values.

Global: **PENDING**




**Step 2: Change in Downstream Flange Check**

Flange	X	Y	Diameter
OUT			
New:	<input type="text"/>	<input type="text"/>	<input type="text"/> in
Delta:	<input type="text"/>	<input type="text"/>	<input type="text"/> in

Diameter:   
**PENDING**  
X and Y: ±0.006 in  
Diameter: ±0.015 in


**Description:**  
Difference between current and previous fiducial values and diameter. If the current diameter is acceptable, only then will the corresponding X and Y vals be updated if either exceed the tolerance.



Final "Upstream Flange" Step (#1465 continued):

QFC015  
Status

<b>Step 3: Upstream Flange Values</b>					
<b>Flange IN</b>	<b>Z</b>	<b>Flange IN</b>			
<input type="text"/>		<input type="text"/>	<input type="text"/>	mrad	
1.852	<b>X</b>	<b>Yaw</b>	<b>Pitch</b>		
0.012	<b>Y</b>				
inches		Meas.	Actual	Nominal Diameter	
<b>Diameter</b>		<input type="text"/>	<input type="text"/>	9.970	<b>PENDING</b>
			in	±0.015 in	
<b>Description:</b>					
Location and orientation of Flange IN (upstream) plus its measured diameter.					
Flange IN X and Y values are also checked ±0.020 in. Yaw 5 to 9 mrad. Pitch ±3 mrad.					



QFC015  
Status

<b>Step 4: QFC Chamber Length</b>					
<b>Length with SMR</b>	<b>Length</b>		Nominal Length		
<input type="text"/>	<input type="text"/>	inches	inches	69.417	<b>PENDING</b>
<b>Description:</b>					
Length should be between nominal value and nominal value - 0.125 in.					

