

A. NLCTA Radiation Safety

A.1 Radiation Safety Systems

Radiation safety is ensured by a number of engineered safety systems and by the administrative measures associated with those systems. The engineered systems are:

- The shielding envelope, which functions as an attenuator of the radiation produced by the accelerated particle beams, such that radiation levels outside the shielding envelope are consistent with worker occupancy, and boundary doses are consistent with permitted off-site levels. The shielding envelope also serves as an access control barrier to prevent personnel from entering high-level radiation areas.
- The Personnel Protection System (PPS), which controls personnel access to the accelerator systems within the shielding envelope in such a manner that personnel access is not permitted when radiation hazards are present.
- The Beam Containment System (BCS), which ensures that the beam remains within the beam path which was envisaged for the shielding design, and acts to terminate operations through independent shut-off channels if there is evidence that the channel has been breached.
- The Beam Shut-Off Ion Chamber (BSOIC) system, which acts as a secondary backup system to detect radiation levels outside the shielding enclosure exceed preset levels (nominally 10 mrem/h). If such is the case, the system terminates operations through the PPS shut-off channels.

Administrative measures include:

- The Beam Authorization Sheet (BAS), which is a document that is required to be completed prior to operation of the beam into any of the possible channels for a particular accelerator. It serves as a detailed prescription of the measures required to ensure that operations remain within the Accelerator Safety Envelope. Signatures are required initially by the Radiation Physicist responsible for the NLCTA, and from the NLCTA Safety Officer, and thereafter signatures are required by operations supervisors on a shift-by-shift basis. The document is the responsibility of the Radiation Physicist assigned to the area concerned and is approved by the Accelerator Department Safety Office.

Each BAS is divided into the following sections:

- Pre-Running Conditions: Provides for the sign off and approval of inspections or check out of radiation safety items including shielding inspection, PPS and BCS items, and BSOICs.
- Initial checkout: Provides for the sign off and approval of any tests to be conducted requiring beam on, such as radiation surveys or ion chamber response calibration.
- Running Conditions: Itemizes all radiation safety items required to be in place or active throughout the period of beam operation. Also included are allowable beam power limits and beam destinations for the area under consideration.

- Changes or additions: During a running period changes or additions to any part of the BAS may be made with the joint approval of the Radiation Physicist and the Accelerator Department Safety Office (ADSO).
- Operator Sign-Off Sheets: The Operator in Charge is responsible for ensuring that the Running Conditions are complied with during beam operation and signs at the beginning of the shift to acknowledge any changes or additions that have been made.

Configuration control of radiation safety systems is assured by:

- *SLAC Guidelines for Operations*, which requires written authorization before any work is carried out on any of the radiation safety systems above, and specifies requirements for post-work testing.
- Formality in initial check out, periodic component checks, and semiannual safety system tests which are required to be in accordance with written procedures.

A.1.1 The Personnel Protection System at the NLCTA


The NLCTA PPS Access Control System is a four-state access system:

- Permitted Access
- Controlled Access
- Restricted Access
- No Access

Entry into the NLCTA beam line housing requires verification that all electrical and radiation hazards are off. If the status of any radiation hazard is lost when the housing is in Permitted, Controlled, or Restricted Access, then the PPS Access Control System does not allow transfer to other access states. In addition, an audible alarm sounds at the PPS control console, requiring intervention by the NLCTA operator to investigate. If the “off” status of any radiation hazard is lost while the housing is in the Controlled Access state, all keybank releases are disabled.

The NLCTA beam line housing has two entrance points (Figure A-1). Both are standard access modules. One is located at the west end of the beam line housing, and the other is approximately 3/5 of the way down the housing from the west end. Each access module contains an Outer Door, Inner Gate, Keybank, Access Annunciator panel, Door Control boxes, Emergency Entry/Exit buttons, Search circuit boxes, Telephone, Yellow/Magenta warning lights, and a TV camera (Figure A-2). The outer door uses a magnetic lock (magnalock). This device is an electromagnet which secures the door in the closed position. A circuit monitors this device to ensure its contact with its door stop and monitors its magnet current to ensure proper operation.

The PPS Access Control System is operated from the PPS control console located in the NLCTA Control Room, Building 128. A second panel is located in the PPS backup rack, B062 Rk. 01, and is used by the PPS crew for maintenance and certification purposes only. The logic is designed using fail-safe and redundant relay circuit techniques. Most of the hardware is housed in locked cabinets and racks. Wires and cables are protected in conduit, armored cable, or trays.



Next Linear Collider Test Accelerator (NLCTA)
Beamline Housing Location - General

R. FULLER 12/19/94

Fig. 1

Figure A-1: NLCTA PPS General Layout





Figure A-2: NLCTA PPS Door Configuration

A.1.1.1 Normal Entry and Exit Procedure for Controlled Access

Assuming that the NLCTA facility is in the No Access state, the following procedure is followed to enter the housing under Controlled Access:

- All beam stoppers and electrical hazards are set to their on/off state by the NLCTA operator. The specific stoppers are:
 - S-band rf gun modulator HV charging supply
 - All main power supplies for klystron systems configured to power accelerator structures
- The NLCTA operator sets the access state of the facility to Controlled Access.
- A radiation survey of the beam line housing components is made by a qualified person following long pulse electron beam operation¹.
- At this point, access to the beam line housing is controlled by the NLCTA operator as follows:
 - OHP individuals requesting access to the beam line housing are identified and logged in by the NLCTA operator via visual and audio communication at the point of entry.
 - Once logged in by the operator, a key release push button is pressed by the operator at the PPS control console. While the push button is held down, each individual removes one key from the keybank. This key is to be kept in the personal possession of the individual throughout his/her stay in the housing.
 - Once a key has been released to each individual, one individual of the group inserts his/her key into the Door Control box, rotates the key clockwise, and holds. In concert with this action, the NLCTA operator presses and holds down the door-release push button. The outer door can then be opened and the individual can remove and retain his/her key. Those individuals with keys are monitored and allowed to pass through the outer door. Once all individuals have passed through the outer door, and the last individual entering has closed the outer door the NLCTA operator can then release the door-release push button.

Note: If, for any reason, the door-release push button is released prior to the closure of the outer door, the search circuit is faulted, requiring a re-search of the housing by qualified operators.
 - Individuals can immediately pass through the inner gate following the outer door. The inner gate is to be left in the open position for the duration of the access.
 - To exit the housing, an individual must contact the NLCTA operator, request to exit, and insert and rotate the key in the control box. In concert with this action, the NLCTA operator depresses and holds down the door-release push button while the individual exits through and closes the outer door. The NLCTA operator may now release the door release push button.

¹ The long pulse operation is only possible with the thermionic gun, which is currently not installed. The Radiation Posting of the enclosure is updated as the configuration changes.

Note: If, for any reason, the door-release push button is released prior to the closure of the outer door, the search circuit is faulted, requiring a search of the beam line housing by qualified operators before operations can resume.

- After the radiation survey is completed and OHP has approved occupancy, the NLCTA operator controls access to the housing through either the east or west access modules by the release of keybank keys as outlined in the fourth step above.

A.1.1.2 Normal Entry and Exit Procedures for Permitted Access

Assuming that the NLCTA facility is in the No Access state, the following procedure is followed to enter the beam line housing under Permitted Access:

- All beam stoppers and electrical hazards are set to their on/off state by the NLCTA operator.
- The NLCTA operator sets the access state of the facility to Controlled Access.
- A radiation survey of the beam line housing components is made by Operational Health Physics (OHP) technicians as necessary, arranged for by the NLCTA operator.
- After the radiation survey is completed and OHP has approved occupancy, the NLCTA operator sets the access state to Permitted Access. Setting this state automatically releases the Search Reset status.
- At this point, any individual can enter or exit through either gate into the housing.

A.1.1.3 PPS Security Fault Violations

A Security Fault violation can only occur in the No Access, Restricted Access, or Controlled Access states.

- A Security Fault violation in the No Access and Restricted Access states is defined as:
 - Operating the Emergency entry/exit button at the outer doors located at the Access Modules.
 - The act of opening the inner gate at either of the NLCTA Access Modules.
 - Operation of any Emergency Off push button (five each) along the aisle way inside the NLCTA beam line housing and access mazes.
- Loss of keybank “complete” status.

Any of these Security Fault violations remove the PPS permits to all radiation and electrical hazards.

A Security Fault violation in the Controlled Access state is defined as an Emergency entry or exit through the outer door located in the Access Modules.

All of the above Security Fault violations result in a loss of the Search status, thus requiring a re-search of the NLCTA beam line housing. The loss of Search status does not change the access state. There are no Security Fault scenarios for the Permitted Access mode.

A.1.1.4 Search Circuit — NLCTA Beam Line Housing

The Search circuit for the NLCTA beam line housing is comprised of two Search Preset boxes located at the west and east ends of the housing. A Search Reset box is mounted outside the housing at the east Access Module entry. All preset and reset boxes require a key for actuation. The search logic requires that the NLCTA be set to Controlled Access prior to any search activities. The locations of the Search Reset and Preset boxes are shown in Figure A-1.

The Search Reset is complete when:

- The Search Presets for the housing are set.
- All gates and doors are closed.
- The Emergency Off buttons are reset.
- Both Access Module keybanks are “complete.”
- The searcher outside the housing at the east Access Module and the NLCTA PPS operator at the control room console push their respective Search Reset button simultaneously to set the Search Reset.

After the Search Reset is set, setting the NLCTA back to Permitted Access or having a Security Fault will trip the Search Reset circuit.

A.1.1.5 Visual and Audio Warnings

Both visual and audio warnings are activated when the access state of the NLCTA beam line housing is set to Restricted Access and No Access. When the housing is set to Restricted Access, the housing lights and Emergency Off pilot lights flash and a recorded warning message is played for approximately 2 minutes. The message is:

“Attention. The Electrical Hazards are about to come on. Press the nearest Emergency Off button and call extension 5481 immediately.”

When the housing is set to No Access the housing lighting flash and a recorded warning message is:

“Attention. The beam is about to come on. Press the nearest Emergency Off button and call extension 5481 immediately.”

The flashing lights and message continue for 2 minutes. No permits to radiation hazards will be issued by the PPS until this message has timed out without the activation of an Emergency Off button or the opening of a housing gate. Should an Emergency Off button be pushed during the warning cycle, the warning message is terminated, and the Search circuit is faulted. If either inner gate is opened, the warning message is terminated, the Search circuit is faulted, and the housing lights come on full bright.

A.1.1.6 PPS Keybanks

There are two keybanks, one at the entrance of each Access Module. Both keybanks are required to be complete in order to transfer from Controlled Access to Permitted Access.

A.1.1.7 PPS Emergency Off

The Emergency Off circuit is comprised of five push button boxes located along the aisle way of the housing and in the access mazes. The five boxes inside the housing are identified with signs “Beam Emergency Shut Off.”

With the housing in the Restricted Access or No Access modes, pushing any of these buttons creates a Security Fault. With the NLCTA in Controlled Access the buttons are not active. Each push button station will be tested by the search team for trip status. The reset function of the Emergency Off circuit can only be done in Controlled Access.

A.1.1.8 PPS Emergency Entry/Exit

The Emergency Entry/Exit device for the outer door of each NLCTA Access Module is made up of two 4 inch by 4 inch by 6 inch boxes, one located on each side of the outer door. They have red shrouded push buttons located behind clear pull-away covers. Pushing these buttons releases the door magnalock, allowing egress. An audio alarm sounds at the entry/exit point and in the NLCTA control room.

The alarm can be silenced by pushing a button on the NLCTA control room PPS control panel. With the NLCTA in No Access, Restricted Access, or Controlled Access states, making an emergency entry or exit creates a Security Fault.

A.1.1.9 Burn Through Monitors (BTM)

There are no Burn Through Monitors (BTMs) required for the NLCTA at this time.

A.1.1.10 Beam Shut-Off Ion Chamber (BSOIC)

There are presently 10 BSOICs assigned to various locations around the NLCTA enclosure with an additional three assigned to the experimental hall. If radiation levels exceed their preset threshold, the units shut off all radiation hazards. Analog readout and reset function are on the Control Computer. BSOIC analog levels are also be in the control system history buffer.

A.1.1.11 PPS Functionality

Correct functionality of the PPS is assured by the following administrative systems:

- As required by SLAC policy, specific tests of door switches and emergency off buttons are performed by the members of the search team. These tests are described in the NLCTA PPS Interlock Checklists.
- Semi-annual validation is performed on the entire PPS system in accordance with formal procedures published by the Controls Department and approved by the Accelerator Department Safety Office.
- Formal procedures (*SLAC Guidelines for Operations*) which mandate that no work be performed on the system without a Radiation Safety Work Control Form.

A.1.2 NLCTA Beam Containment System

A.1.2.1 Introduction

Beam containment for the NLCTA Facility is achieved by a combination of mechanical and electronic devices.

A.1.2.2 Equipment Description

The simplicity of the NLCTA configuration means that beam containment can be assured by a combination of air-cooled dumps, collimators, and discrete ion chambers.

- Protection Collimators: Protection collimators are installed downstream of the horizontal bend locations (chicane and spectrometer) to prevent an errant beam from targeting the shielding wall.
- Discrete Ionization chambers: Typically, these are argon-filled cylinders about 15 inches long and 4 inches in diameter. High voltage is applied to one of the internal electrodes. The output signal developed on the other electrode is transmitted on coaxial cable to an electronic processing module in MCC or one of the support buildings.

Note: No BTMs are considered necessary.

A.1.2.3 Administrative Procedures

- Beam Authorization Sheet: The Beam Authorization Sheet (BAS) specifies the beam containment devices that must be active or present for each beam line during a running cycle. The BAS is prepared by the Responsible Radiation Physicist and approved by the Accelerator Department Safety Office.

Before each beam running cycle, the electronic devices that are required for each beam line, as defined in the BAS, are validated using written procedures.

- Daily/Weekly Test Procedures: Even though all of the sensors, modules, and their connecting cable plant use self-test signals to ensure system integrity, daily or weekly checks are carried out on all of the BCS equipment that is required to be active by the BAS. This includes verification of trip point settings and confirmation that all shut-off paths are operating normally.
- Configuration Control: Procedures that control the modification and retesting of Beam Containment system are described in the SLAC Guidelines for Operations. All changes must be carefully reviewed and approved, and retesting must be done in accordance with an approved procedure.

A.1.3 NLCTA Beam Shut-off Ion Chamber (BSOIC) System

The NLCTA is located in a 170-foot-long concrete tunnel originating in End Station B. The beam produces negligible radiation along the accelerator except when beam missteering or equipment failure causes significant beam loss. If the beam is not properly contained in its beam path (by the Beam Containment System), elevated radiation levels may exist in occupied areas. To prevent these elevated levels from remaining unnoticed for any length of time, ten interlocked BSOICs have been installed around the shielding perimeter. The BSOICs are connected to the NLCTA Control Room and provide the following output signals:

- An analog signal that gives the actual radiation level at the BSOIC
- A beam interlock signal which acts to shut off the beam when the upper set point is exceeded

A.1.3.1 Locations

- The specific location for each BSOIC is determined by a Radiation Physicist and is based on considerations such as the thickness of shielding and the likelihood of beam missteering or loss at a point in a beam line. These locations are specified in the BAS.

A.1.3.2 Administrative Procedures

- Configuration Control: In accordance with the requirements of the SLAC Guidelines for Operations, all work on the BSOIC system is performed using Radiation Safety Work Control Forms. Personnel who work on these systems are specifically assigned and authorized to do this work.

A.1.4 Radiation Safety Committee Approval for Unattended Operation

The February 7, 2000 memo approving NLCTA unattended operation, RSC-00-001 from Gerry Nelson is located at:

<http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/rsc-00-001.pdf>

A.2 Shielding Design

A.2.1 Design Criteria

The shielding for the NLCTA was designed to limit to 1 rem/y the integrated dose near the surface of the shielding around the NLCTA. This goal was taken to correspond to limiting the continuous dose rate at the surface of the shield in occupied areas to 2 mrem/h, assuming a maximum credible average beam power of 5.75 kW, the nominal beam-loss fractions, beam operation for 1,000 hours per year, and an occupancy factor of one half. The occupancy factor is extremely conservative, since there is no office or other full-time work space immediately adjacent to the NLCTA shielding.

The above design goal implicitly satisfies the DOE requirement for a low-hazard facility: that individual's exposures must never be able to exceed 25 rem in any one hour of operation with maximum credible losses at the maximum credible beam power, in the event that the Beam Containment System fails. Here, "maximum credible losses" means 100% loss in either the chicane or the linac.

A SLAC design guideline [10] further limits, to 3 rem, the total integrated dose permitted in the event of a failure of beam containment. (Beam containment issues are discussed in detail in A.1.2.)

By achieving acceptable dose rates in the areas adjacent to the NLCTA, the shielding design results in negligible doses at the site boundary. See Section A.2.7 below.

The shielding-design calculations indicate the potential, under normal operating conditions for some unoccupied areas such as the roof of the enclosure and the beam dump, to experience doses greater than 5 mrem/h, (in large part because the concrete roof is 4 feet thick, in contrast to the walls which are 6 feet thick). However, some of these calculations are complicated by the presence of vertical penetrations for waveguides and cables. If a radiation survey verifies that these unoccupied areas do indeed experience doses in excess of 5 mrem/h, then they will be designated "radiation areas," and will be identified by warning signs, barriers, and other methods, as appropriate, in accordance

with SLAC policies. No areas outside the NLCTA shielding are expected to be “high-radiation areas,” where continuous doses exceed 100 mrem/h.

A.2.2 Calculation Methods

Most of the shielding calculations for the NLCTA were performed using the computer program SHIELD11. The original algorithm was developed by T. M. Jenkins, based on his empirical measurements [7] and on additional calculations using the electromagnetic shower simulation code, EGS4. SHIELD11 is suitable for calculations of radiation levels behind slab shields resulting from beam losses on thick targets. SHIELD11 calculates total dose (per electron or per kW) and its five separate components:

- GamD — The direct photon component resulting from the electromagnetic shower. It has a sharp maximum in the forward direction and decreases steeply with angle up to approximately 5°, followed by a much milder decrease with angles above that value.
- GRN — Photo-neutrons produced in the Giant Resonance region, mostly by photons with energies below 30 MeV.
- MID — Photo-neutrons resulting from the pseudo-deuteron reactions induced by photons with energies above 30 MeV and up to approximately 300 MeV.
- HEN — High energy neutrons resulting from photo-pion production above the threshold of 140 MeV. This component is the most penetrating and therefore becomes dominant at high energies for thick shields, such as the walls of the NLCTA enclosure.
- CamI — The indirect photon component, generated by nuclear de-excitation and by neutron capture.

Most radiation levels were calculated assuming a “standard” target in SHIELD11: a 12-inch long iron cylinder with a 2-inch radius. Neutron attenuation in the target was neglected. Only for the beam dump, were different target materials or target sizes used.

When it was necessary to use additional methods and “rules of thumb,” the source terms often were calculated using SHIELD11. Only photon and neutron doses were of concern in the shielding calculations, except for the beam dump, where the potential for a muon dose in the forward direction was examined.

A summary of the beam parameters, expected beam losses, and resulting radiation levels in various areas of NLCTA is presented in the Appendix (Table A) of Reference [11].

A.2.3 Beam Line Enclosure

A.2.3.1 General Considerations

When the magnitude of expected beam losses is considered, it is practical to divide the beam line (excluding the dump) into two regions. The first region is the upstream one-third of the beam line, the injector, and chicane, where a large fraction of the beam power is lost. The second region is the downstream two-thirds of the beam line, the linac and the spectrometer, where power losses is less than 7.25W. The thickness of the concrete shielding is the same in both regions: 6 feet for the walls, and 4 feet for the roof. Parts of the two entrance mazes have walls 3 feet thick. The 3-foot and 6-foot lateral walls and the 4-foot roof all are constructed from specially-designed concrete blocks that interlock in order to prevent direct streaming of radiation. The contact surfaces of the wall blocks

have interleaving 4-inch steps (see Figure A-3). The roof blocks are wedge-shaped so as to permit them to interlock in alternating “up” and “down” orientations, as illustrated in Figure A-3.




Figure A-3: Longitudinal Elevation View of the Roof Blocks

In some corners of the beam line enclosure and the mazes, the wall blocks do not interlock as perfectly as was intended. The resulting gaps in these locations have been filled with concrete so as to avoid thin spots in the shield.

A.2.3.2 The Upstream Beam Line (Chicane)

Net beam loss of 37.5 W is expected in the chicane bends and collimators. The maximum beam energy in this area is approximately 60 MeV. At these energies, the largest contribution to the dose rates at the side walls and on the roof comes from the photon component. The bend magnets and collimators were modeled in SHIELD11 as standard iron targets, 12-inch deep with a 2-inch radius. Inside the shielding enclosure, local shielding of bend magnets has been installed to prevent tripping the Protection Ionization Chambers (PICs) located in the enclosure, downstream from the chicane. Such local shielding near the beam line additionally will reduce radiation levels on the roof.

The west end of the shielding enclosure, near the outer PPS gate, consists of only 3 feet of concrete perpendicular to the beam axis. If no additional shielding were present, radiation levels near the entrance to the west maze resulting from expected losses in the chicane could reach 1.4 mrem/h. However, the very small solid angle subtended by this short wall, as seen from the chicane, is completely shadowed by magnets and other beam line components. Consequently, the radiation level are expected to be significantly less than 1 mrem/h.

A.2.3.3 The Downstream Beam Line (Linac and Spectrometer)

Losses in the linac and spectrometer are not expected to exceed 7.25W of beam power under normal running conditions. The highest dose rates under normal conditions are expected near or beyond the end of the linac, where the energy of the beam is greatest. The roof will be posted as a radiation area if the roof dose is measured to exceed 5 mrem/h.

A.2.3.4 Beam Dump

Configuration: The NLCTA dump is a large block of iron (approximately 10 feet by 15 feet by 6 feet) consisting of 6 superimposed iron slabs. The slab on which the beam will be centered is 13 inches thick, and all other five slabs have a thickness of 11.75 inches. The beam will be dumped in two possible locations: either straight ahead or at 12° with respect to the accelerator axis, depending on whether the spectrometer magnet is off or on, respectively. Details of the front part of the dump are shown in Figure A-4.




Figure A-4: Vertical Section of the Front Face of the Beam Dump

- External Shielding: In addition to the neutron and gamma radiation, the potential for a muon dose in the forward direction behind the dump was evaluated. After examining the muon energy-range tables in the computer program MUON89, it was concluded that the muons will not be an issue, since they will range out in the material of the dump. A similar conclusion was reached independently by Lavine [8].

In the forward direction, there is approximately 8 feet of iron followed by 12 feet of concrete. The radiation levels outside the enclosure during normal operation will be negligible. The maximum achievable dose rate at 0° is estimated to be 0.01 mrem/h. Lateral shielding for forward angles (less than 90° with respect to the beam direction) consists of at least 5.5 feet of steel and 6 feet of concrete for both dump lines and will ensure negligible radiation levels. The space created by the recess of the central slab will be filled with solid steel, which will be adjacent to the 8-inch lead shielding immediately surrounding the beam pipes, as shown in Figure A-5. For angles greater than approximately 120° (that is, backwards) with respect to the beam direction, the rays are no longer fully contained by the steel. However, their path length through the concrete side walls increases with increasing angle. The maximum dose rates, which are expected at angles between 130° and 135° , are estimated to be 0.01 mrem/h. The maximum dose rates expected on the unoccupied 4-foot-thick concrete roof are 0.3 mrem/h.

A minor addition to the dump design was performed after its construction was completed. Since some steel plates were not perfectly flat, slight gaps between the plates were found on the front face of the dump. A 3/4-inch gap between the central plate and the one immediately above was filled with grout, filling from the central cavities towards the sides. The efficiency of this modification will be verified during the initial radiation surveys. Depending on the survey results, vertical steel plates could be inserted, if necessary, into the few inches of space remaining between the steel stack and lateral walls.




Figure A-5: Horizontal Section of the Front Face of the Beam Dump at Beam Line Elevation

- **Shielding Against Activation Products:** Since the dump absorbs most of the beam power produced by the facility, it will be the single most activated component and potentially the most important radiation hazard when the enclosure is opened for access after a beam running period. Using Swanson's data for saturation activities induced by high-energy electrons in iron (see Reference [1], p. 110, Tables XXIIa and XXIIb), we can deduce that the nuclides needed to be considered in shielding against the photons from the activated dump are Sc-46, V-48, Cr-51, and Mn-54. Their half-lives are between 16 and 303 days, so a waiting period before entering the enclosure would not be a viable alternative to shielding. Most of the photons emitted by these nuclides lie in the energy interval of 0.8–1.3 MeV. Although the saturation activities from two additional nuclides, Fe-53 and Fe-55, are fairly high, their photon energies (378 keV and 5.9 keV, respectively) are lower and will be subject to a much stronger self-absorption in iron itself.

The sum of the saturation dose rates from the four nuclides above is estimated to be approximately $2.0 \text{ rad}\cdot\text{m}^2/\text{kWh}$, neglecting self-attenuation. De Staebler [2] calculated self-attenuation factors in iron for photons resulting from activation by a high-energy electron beam. For photon energies around 1 MeV, a factor of 0.1 is appropriate. Assuming beam power of 1,500 W, with self-absorption taken into account, the estimated dose rate at 50 cm from the surface of the dump (from the point of beam impact) will be 1.2 rad/h.

In order to simplify shielding against photons from activation products while taking advantage of the available mass of iron, the front face of the 13-inch-thick slab will be recessed by approximately 70 cm. The photon shielding will then consist of an 8-inch (20.3-cm) layer of lead filling the front face opening, as shown in Figure A-5. This thickness is more than enough to reduce the photon dose rate below 1 mrem/h outside the beam pipe. The Tenth Value Layer (TVL) in lead for Co-60, which has photon energies similar to our case, is 4.0 cm [3]. Three TVLs (12 cm) will reduce the dose rate by a factor of 103.

A.2.3.5 Mazes

The entrance mazes were configured so that radiation from any potential source streaming through the maze will be attenuated by a sufficient number of wall reflections and the total length of the radiation path. The source terms were calculated using SHIELD11 at various locations and followed by simple calculations using the inverse-square variation with distance and a “rule of thumb” for wall reflections. It was assumed that the dose is attenuated for each reflection by a factor of 10 for neutrons and 100 for photons¹. Since a minimum of two reflections is needed in both mazes, the neutron component will strongly dominate. Many possible trajectories were traced through the mazes in order to find the maximum radiation level at the entrance.

A.2.3.6 West Maze:




Figure A-6: Plan View of the West Maze and the Beam Line Up to the Chicane Area

The layout of the west maze is shown in Figure A-6. The main radiation sources in the west maze will be the first chicane bend or the collimator in the middle of the chicane, where 75W of beam power may be lost continuously. Losses in the injector could constitute another source, although these are not expected to be as high. Considering many possible trajectories, the estimated dose rates at the inner PPS gate resulting from 250W losses in the first chicane bend will be below 1 mrem/h and therefore even lower at the outer PPS gate, which is the point of interest. Total loss of the beam in the injector would result in neutron-dominated doses just below 2 mrem/h at the inner PPS gate, and doses less than 0.5 mrem/h at the outer PPS gate.

¹ The factor is the ratio of the dose rate at the point of impact to the dose rate due only to reflected radiation at a distance of 1 m from the point of impact in any direction.

A.2.3.7 East Maze:




Figure A-7: Plan View of the East Maze

The layout of the east maze is shown in Figure A-7. Due to relatively lower beam power losses and larger distances involved (relative to the west maze), the radiation streaming through the maze will lead to negligible dose rates at the inner PPS gate. Only the radiation transmitted directly through the shielding is of concern here. A corner between a large and small concrete block (labeled “1” in Figure A-7) constitutes a potentially weak spot for radiation exiting under an angle of approximately 35°. Without additional shielding, dose rates of 1.6 mrem/h outside the maze could be expected from normal beam losses. An additional steel plate 2 inches thick and 2 feet wide was fixed to the concrete block in the critical area inside the maze, reducing expected dose rates below 1 mrem/h. Radiation transmitted through the 3-foot-thick concrete wall in front of the outer PPS gate (see label “2” in Figure A-7) will generate dose rates below 0.9 mrem/h.

A.2.3.8 Utility Tunnels

The NLCTA enclosure was built above two existing underground utility tunnels. (See Figure A-1.) Each of these tunnels originally communicated with the NLCTA enclosure by a manhole 6 feet by 3 feet, as pictured in Figure A-8. The tunnels are perpendicular to the beam line. One of them is located under the chicane area and the other under the spectrometer area.




Figure A-8: Cross-Sectional View of a Utility Tunnel and Manhole

Since access to the tunnels will be possible during NLCTA operation, it was necessary to fill both manholes with shielding material. The radiation safety considerations are somewhat different in each case.

A.2.3.9 Chicane Manhole

The manhole in the chicane area is located under the collimator, where continuous losses of 75 W of the beam power are expected. The full 5-foot depth of the manhole is filled with concrete, supported from the bottom by a 1-inch-thick steel plate. Four penetrations were created on the far edge (away from the beam line) of the manhole: two 6-inch diameter penetrations each contain a 2-inch diameter water pipe and its thermal insulation; and two 4-inch diameter penetrations are unused at this time and available for future use. The unused penetrations will be filled with sand.

Without these penetrations, the expected dose rates in the tunnel below the filled manhole would be around 3 mrem/h at a height of 7 feet. Due to potential for radiation streaming and ducting through the penetrations, in particular through the very low-density thermal insulation, dose rates above 5 mrem/h are not unlikely. The tunnel will be therefore posted as a Radiation Area at its existing PPS gates, which will be neither locked nor interlocked during NLCTA operation. Although radiation workers might occasionally access this tunnel when the beam is on, installation of a BSOIC (Beam Shut-Off Ion Chamber) is not planned. Unlike in most other areas, substantial and continuous beam losses are expected, and 250 W beam loss in the chicane will only triple the normally expected dose rates. As a consequence, if higher than expected dose rates are found during radiation surveys, installation of local shielding might be preferable from the operational point of view and also in limiting potential radiation exposure.

A.2.3.10 Spectrometer Manhole

The manhole under the spectrometer area is filled with 3.5-foot-thick concrete shielding. (It was not possible to fill the whole manhole depth of 5 feet because of interference with LCW valves.) Two 4-inch LCW pipes penetrate the shield at its eastern edge. Since the LCW pipes have no insulation layer and will be filled at all times with water, serious radiation ducting is not expected. If the expected 0.6 W beam loss at 800 MeV at a single point immediately upstream of the manhole, then dose rates up to 1.2 mrem/h could be anticipated at a height of 7 feet in the tunnel, qualifying the tunnel as a Radiation Area. (The simultaneous dose rate anticipated outside the lateral shielding walls is 0.1 mrem/h.) The tunnel has been posted with standard signs as a Radiation Area. Swinging barriers, which will not interfere with emergency egress in the event of a fire, have been installed in the tunnel on both sides of the manhole, at least 2 meters from its edges.

To prevent extended duration of elevated dose rates a BSOIC with a 100 mrem/h trip threshold is installed in the tunnel under the manhole. The BSOIC in the tunnel will shut off the nominal beam when dose rates exceed 100 mrem/h.

A.2.3.11 Penetrations

- Roof Penetrations: Four penetrations 6 inches in diameter were made through the roof blocks to accommodate waveguides. The waveguides themselves are 3 inches in diameter. Radiation streaming through these penetrations will lead to higher radiation levels on the roof. This effect can be substantially reduced in the case of electrical cables by dense packing and by filling the remaining free space with additional shielding material. However, such techniques obviously are not applicable for evacuated waveguides. All penetrations are situated near the lateral wall, to avoid direct view of the beam line from the roof through the ducts, which would lead to Extremely High Radiation levels.
- Additional penetrations through the concrete shielding were made as follows:
 - a. Four penetrations were added to the roof and north wall in 2003 for the E163 experiment. The geometry and radiation impact of these penetrations is described in the April 10, 2003 memo from H. Y. Khater and H. Vincke to S. Rokni, Section A.2.11.1.
 - b. Five penetrations were added to the roof in 2004 to accommodate the 8-pack experiment. The geometry and radiation impact is described in the January 8, 2004 memo from H. Khater to S. Rokni, Section A.2.11.2.
 - c. One more penetration will be added to the roof in 2006 to accommodate an L-band waveguide. The geometry and radiation impact is described in the June 1, 2005 memo from H. Khater to S. Rokni, Section A.2.11.3.




Figure A-9: Schematic View of the rf Waveguide Passing Through a Roof Penetration

In order to estimate the radiation levels above an empty penetration, the source term at the entrance of the penetration was calculated using SHIELD11. Two separate cases were considered. The first estimate assumed the maximum energy achieved at the end of the accelerator was 800 MeV with nominal beam losses (0.5%). The second estimate was done for the region around the waveguide penetration for station 1, where the energy was assumed to be 120 MeV, and assumed 100% beam loss. The loss was assumed to occur at a single point near the penetration. The neutron source term was doubled in order to account for the contribution of scattering off the interior walls of the enclosure [9]. Photon and neutron ducting factors were then calculated using the computer program DUCT [9], and applied to obtain the dose rate at the exit of the duct. This was calculated to be 305 mrem/h. The geometry of the problem is represented in Figure A-9.

Dose rates due to radiation penetrating the 4-foot concrete roof will be less than 10 mrem/h. Radiation penetrating through the roof from point losses will cover a much larger area of the roof than radiation ducting through the opening of a waveguide. It follows that the relative contribution of a penetration to skyshine at the site boundary will be small and that dose rates of 10–100 mrem/h at the penetration exit can be tolerated, so long as the roof is posted as a Radiation Area.

A.2.4 Air Activation

When the bremsstrahlung, which results from beam losses along the beam line, is not absorbed in the beam line components, it escapes into the surrounding air volume and causes air activation. The average room concentration can be calculated using the following equation:

$$(AverageRoomConcentration) = (SaturationActivity) \times \left(\frac{BremsstrahlungPathlength}{RoomVolume} \right)$$

where the saturation activity in units of Bq/m/kW or mCi/m/kW are available from the literature [1] [5]. The beam loss scenario adopted in this case assumes that 0.5% (that is, 7.5 W out of 1,500 W) of the total beam power is being lost in one discrete point at the end of the accelerator structure. The path length of the bremsstrahlung that barely misses Quad 1760 is approximately 11 m before it hits the enclosure wall. This scenario is more conservative than considering 0.5% losses distributed along the beam line, which would

lead to lower energy losses and shorter photon paths. The total volume of the beam line enclosure is 500 m³.

Table A-1 contains a list of potential activation products in air, predicted concentrations at saturation, and Derived Air Concentration (DAC) limits from DOE Order 5480.11 [4]. The values for saturation activity were taken from Swanson [1], with the exception of N-13 and O-15, where more recent values from Ferrari et al. [5] were used. According to Swanson, even without forced ventilation, a complete air change occurs several times per hour. Due to their long half-lives, it is not possible to accumulate a sizable fraction of the saturated activities of H-3 and Be-7. The most important nuclides to be considered here are N-13 and O-15. It is clear from the above results that predicted levels will be lower than the DOE limits by at least an order of magnitude.

The allowed DAC limits specified in

Table A-1 are taken from DOE Order 5480.11 [4]. These limits are identical to the limits specified in 10 CFR 835, except for the isotopes C1-38 and C1-39, for which the DOE limits are the more restrictive.

It should be noted that there are several levels of conservatism embedded in both the calculations and the used DAC values. The DOE-imposed DAC values are based on external whole-body exposure of radiation workers from immersion in a semi-infinite hemispherical cloud for 40 hours per week. Since the air volume inside the NLCTA enclosure is substantially limited in comparison with a semi-infinite hemispherical cloud, higher DAC values could be used. Also, since the enclosure can be accessed only when the beam is off, the saturation concentrations will quickly diminish due to decay and ventilation, preventing any continuous exposure of workers to the levels at saturation.

Table A-1: Potential Activity Induced in Air

Nuclide	Half Life	Reaction Type	Saturation Activity [MBq/kWm]	Concentration [Bq/cm ³]	Concentration [mCi/cm ³]	DAC [mCi/cm ³]
H-3	12.2 y	(γ ,H-3)	5	7.03E-4	1.90E-8	2.00E-6
Be-7	53.6 d	(γ ,sp)a	1	1.41E-4	3.80E-9	9.00E-6
C-11	20.3 m	(γ ,sp)*	10	1.41E-3	3.80E-8	4.00E-6
N-13	10 m	(γ ,n)	200	2.81E-2	7.60E-7	4.00E-6
O-15	123 s	(γ ,n)	130	1.83E-2	4.94E-7	4.00E-6
N-16	7.14 s	(γ ,np)	0.02	2.81E-6	7.60E-11	7.00E-7
Cl-38	37.3 m	(γ ,p)	0.22	3.09E-5	8.36E-10	3.00E-6
Cl-39	55.5 m	(γ ,p)	1.5	2.11E-4	5.70E-9	3.00E-6
Ar-41	1.8 h	(n, γ)	—	4.94E-3	1.42E-7	3.00E-6

The saturation activities reported in literature and used in

Table A-1 are usually calculated for target composition and geometry that maximize bremsstrahlung production. On the other hand, beam losses in the NLCTA beam line are likely to happen in beam line components that are substantially thicker than the optimum target, leading to relatively lower bremsstrahlung leakage and air activation. Furthermore, a major part of the energy carried away by bremsstrahlung is confined to narrow forward angles, which will be considerably shielded by the presence of the accelerator structure and/or beam line components downstream from the point of beam loss.

A.2.5 Ozone Production

Ionizing radiation interacting with the air inside the NLCTA enclosure is a likely source of ozone, an industrial-hygiene hazard. Potential ozone concentrations were estimated using a method described by Swanson [12], under conservative assumptions similar to those taken by Jenkins [13].

As in the case of air activation, the source of radiation considered was 0.5% loss at the high-energy end of the linac. Assuming that the beam line enclosure is unventilated, a saturated ozone concentration will arise due to the equilibrium between the production rate (p) per minute and the decay rate which is characterized by a half-life (T) of 50 minutes. The saturated ozone concentration will be $C_s = pT / V$.

The volume (V) of the enclosure was estimated to be 500 m^3 . To estimate the production rate at the end of the linac, it was assumed that 5% of the lost power, that is, 75 W, escapes from the beam line components into the air, which is conservative for thick targets. It was furthermore assumed, again quite conservatively, that all this escaping power is carried by 10-MeV electrons with $dE/\rho dx = 2 \text{ MeV g}^{-1} \text{ cm}^2$, and that the average electron path through the air will be 5 m. It follows from the above that 13% of the escaping energy will be absorbed in the air, at a rate of $2.03 \cdot 10^{17} \text{ eV/s}$. Using a conservative “G-value” of 10 molecules generated per 100 eV absorbed, and assuming instantaneous air mixing within the enclosure, the calculated production rate of ozone molecules is $4.12 \cdot 10^7 \text{ cm}^{-3} \text{ s}^{-1}$, resulting in a saturated concentration of $1.24 \cdot 10^{11} \text{ molecules/cm}^3$, which represents a fraction of $4.61 \cdot 10^{-9}$ of the air molecules. Since the Threshold Limit Value (TLV) for ozone is 10^{-7} , our very conservative estimate of concentrations due to losses at the end of the linac will be less than 5% of TLV.

When the beam in NLCTA is stopped to permit personnel access, ozone concentrations will decrease exponentially with the characteristic half life of 50 minutes. Opening a PPS door will further accelerate this decrease due to venting of ozone through the doorway.

The above estimates indicate a negligible ozone hazard to personnel entering the NLCTA housing after beam operation. Nevertheless, actual ozone levels will be verified by empirical sampling as higher and higher beam power levels are achieved. In the unlikely event that unsafe ozone levels are ever encountered, the health hazard will be mitigated by requiring a “waiting period” of sufficient duration for the ozone to disintegrate before entry into the NLCTA housing is permitted after beam operation.

A.2.6 Ionizing Radiation from Klystrons

The X-band klystrons, the S-band klystron, and the L-band klystron used to generate microwave power can be sources of ionizing radiation. The waveguide network which is used for pulse shaping can also be a source of ionizing radiation. The dose rate from these sources varies among individual klystrons, but is in the range of 0–25 mrem/h at 30 cm from the envelope of the tube. Local lead shielding has been applied to mitigate the hazard, and areas which have dose rates in excess of 5 mrem/h will be roped off and signed as Radiation Areas.

A.2.7 Site Boundary Dose

The predominant component of the boundary dose is secondary radiation from the primary beam, in the form of skyshine neutrons. Other, much smaller components are airborne activation products (radioactive gases) and klystron X-rays. These sources and their respective attenuations are discussed below. The site boundary monitoring system is also discussed.

A.2.8 Prompt Radiation

The distance from the NLCTA to the closest point of the SLAC boundary is approximately 400 m. The dose at this point will be caused by skyshine neutrons leaking through the roof and scattering in the air. Calculations of the boundary dose were performed using the computer program SKYSHINE, written by T. M. Jenkins. Two source terms were taken into account:

- 0.5% beam loss in the accelerator structure 70% of the running time ($1.4 \cdot 10^{17}$ e⁻/y),
- 100% beam loss in the beam dump 70% of the running time ($2.8 \cdot 10^{19}$ e⁻/y).

The boundary dose from both source terms was found to be negligible:

- 0.02 mrem/y for the accelerator structure,
- 0.0001 mrem/y for the dump.

Furthermore, the algorithm in SKYSHINE is certain to yield conservative results for narrow and elongated geometries such as the NLCTA roof. Consequently, the boundary dose will be no greater than the sum of the sources, 0.02 mrem/y.

A.2.8.1 Airborne Activation Products

The dose at the site boundary due to airborne transmission of air-activation products from the NLCTA enclosure was analyzed [14] for compliance with the Environmental Protection Agency's National Emissions Standards for Hazardous Air Pollutants ("NESHAPS") [15], using the computer program "CAP88-PC [16]. Based on the radioactive source concentrations discussed in Section 7.2.4 ("Air Activation"), the effective dose equivalent to the maximally exposed individual of the general public was found to be $1.5 \cdot 10^{-4}$ mrem/y. This is considered acceptable, as it is well below the 10 mrem/y dose permitted by NESHAPS.

A.2.8.2 Klystron X-rays

Ionizing radiation from the NLCTA klystrons was discussed in Section 4.5. The dose at the site boundary due to the NLCTA klystrons is reduced to a negligible level by several significant factors: The NLCTA klystrons are located inside End Station B. The 2-foot-thick concrete walls of the End Station attenuate the X-ray dose by approximately 10^{-6} . The 400-m distance to the site boundary provides a further reduction by approximately 10^{-6} , relative to the 30-cm dose, due the inverse distance-squared factor. Still further reduction of the boundary dose is provided by large earth berms shielding the line of sight from the End Station to the site boundary.

A.2.8.3 Monitoring the Boundary Dose

The SLAC boundary is continuously monitored by an existing system of detectors, both active and passive, which are sensitive to neutrons and gamma-rays. The active detectors (moderated BF_3 tubes for neutrons and Geiger-Muller tubes for photons) are read out and logged every 6 minutes. They are positioned at seven locations which are forward-directed relative to the primary radiation sources of the linac. Since the NLCTA's beam line is nearly parallel, the NLCTA is well served by the existing, active monitoring system. In addition to the active monitors, neutron and photon thermo-luminescent dosimeters, TLDS, are located at 35 monitoring stations distributed roughly uniformly along the site boundary. The cumulative doses in these passive monitors are read every three months.

A.2.9 Section References

- [1] Swanson, W. P., "Radiological Safety Aspects of the Operation of Electron Linear Accelerators," Technical Report Series No.188, IAEA, Vienna, 1979.
- [2] De Staebler, H., "Photon-Induced Residual Activity," SLAC TN-63-92.
- [3] *The Health Physics and Radiological Health Handbook*, edited by B. Shleien, Scinta, 1992.
- [4] DOE Order 5480.11, "Radiation Protection for Occupational Workers," US Department of Energy, Washington, DC, 1988.
- [5] Ferrari, A., Pelliccioni, M., and Salla, P. R., "Bremsstrahlung Source Terms for Intermediate Energy Electron Accelerators," Nuclear Instruments and Methods in Physics Research B 82, 1993, pp. 32–38.
- [6] Paterson, H. W. and Wallace, R., "A Method of Calibrating Slow Neutron Detectors", UCRL-8359, 1958.
- [7] Jenkins, T. M., "Neutron and Photon Measurements Through Concrete from a 15 GeV Electron Beam on a Target — Comparison with Models and Calculations," Nuclear Instruments and Methods in Physics Research 159, 1979, pp. 265–268.
- [8] Lavine, T. L., Memorandum to N. Ipe and the SLAC Safety Overview Committee, October 8, 1993.
- [9] Jenkins, T. M., private communication. This estimate of the contribution of scattered neutrons is based on Jenkins' unpublished calculations based on the MORSE neutron-photon transport code and DESY measurements.
- [10] Nelson, G., "Beam Containment Policy and Implementation," SLAC Memo to the Radiation Safety Committee, May 18, 1994.

[11] Browne, M.J., “Average Current Limit of the NLCTA Thermionic Gun,” NLCTA Note #48, May 30, 1995.

[12] Reference [1], pp. 149–155.

[13] Jenkins, T. M., “Radioactive Air and Ozone Concentrations in the Cooling Vault,” Single Pass Collider Memo CN-51 (SLAC internal report), April 30, 1981.

[14] R. Sit, “NESHAPS Compliance Assessment for NLCTA Operations,” memo to V. Vylet, dated August 10, 1995.

[15] 40 CFR 61, Subpart H.

[16] CAP88-PC, “Clean Air Assessment Package,” 1988.

A.2.10 Section Bibliography

Browne, M. J., “Analysis of Failure Modes of the Average Current Limit for the NLCTA Thermionic Gun,” NLCTA Note #51, September 26, 1995.

Independent confirmation of the results found in Browne, M. J., “Analysis of Failure Modes of the Average Current Limit for the NLCTA Thermionic Gun,” NLCTA Note #51, September 26, 1995, was requested by the SLAC Radiation Safety Committee on June 6, 1995. This confirmation was provided by Len Genova, in two Memoranda addressed to Ted Lavine, dated July 23, 1995 and July 27, 1995. Copies of these memoranda have been filed with the SLAC Radiation Safety Committee.

Kase, K. R., “Design of Accelerator and Experimental Facilities — Failures, Accidents, and Redundancy,” internal SLAC document, March 16, 1994.

Kase, K. R., “Radiological Protection Guidelines for Primary and Secondary Beamlines in the Research Yard,” internal SLAC document, January 21, 1994.

SLAC Radiological Control Manual, SLAC-I-720-0A05Z-001, latest revision.

Smith, H., Fuller, R., and Bong, P., “Proposed PPS Access Control System for the NLCTA,” NLCTA Note #45, March 30, 1995.

Walz, D. memoranda to T. Lavine: “NLCTA Beam Dump” (October 6, 1993) and “NLCTA Beam Dump — Revisited” (May 12, 1995).

A.2.11 Penetration References

A.2.11.1 April 10, 2003 Memo describing Penetrations added for E-163

The April 10, 2003 memo describing penetrations added for E163 from Sayed Rokni is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/E163_pene_030410.pdf

A.2.11.2 January 8, 2004 Memo Describing Penetrations added for the 8-Pack Experiment

The January 8, 2004 memo describing penetrations added for the 8-Pack from Sayed Rokni is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/8Pack_pene_040108.pdf

A.2.11.3 June 1, 2005 Memo Describing the L-Band Penetration

The June 1, 2005 memo describing a penetration added for the L-Band system from Sayed Rokni is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/LBand_pene_040108.pdf

B. Experimental Hall Radiation Safety

B.1 Maximum Credible Beam Power Calculations for the New Photoinjector

B.1.1 September 8, 2004 Memo describing Explosive Electron Emission (EEE) for E-163

The September 8, 2004 memo describing Explosive Electron Emission for E163 from Eric Colby is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/EEE_040908.pdf

B.1.2 November 16, 2005 Memo revisiting Explosive Electron Emission (EEE) for E-163

The November 16, 2005 memo revisiting Explosive Electron Emission for E163 from Eric Colby is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/EEE_051116.pdf

B.1.3 May 27, 2005 Installation of New Electron Source at the NLCTA Memo

The May 27, 2005 memo describing the installation of a new electron source at the NLCTA from Eric Colby is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/ElecSource_050527.pdf

B.1.4 July 27, 2005 New Electron Source at the NLCTA

The July 27, 2005 memo requesting approval of the installation of a new electron source at the NLCTA from Heinz Vincke is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/ElecSource_050727.tif

B.1.5 August 1, 2005 New Electron Source at the NLCTA

The August 1, 2005 memo approving the installation of a new electron source at the NLCTA from Sayed Rokni is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/ElecSource_050801.tif

B.2 Experimental Hall Shielding Design

B.2.1 October 17, 2005 Radiation Safety Analysis of E-163 – Laser Acceleration of Electrons in Vacuum

The October 17, 2005 Radiation Physics Note, RP-05-24 describing the radiation safety analysis of E-163 – Laser acceleration of electrons in vacuum is located at:

http://www-project.slac.stanford.edu/lc/local/Projects/NLCTA/Supporting-documentation/RP-05-24_051017.pdf

B.3 Experimental Hall Personnel Protection System Design

SLAC document SD-235-977-58 describes the Experimental Hall Personnel Protection System Design.

B.4 Laser Personnel Protection System Design


B.4.1 Safety System Design

SLAC document SD-235-977-50 describes the Laser Personnel Protection System Design.

B.4.2 Laser Safety System Certification Procedure

The certification of the Laser Safety System is conducted by the PPS Group according to a pre-approved procedure. This procedure is documented as CPE Procedure 18-29-10-03-NLCTA-IAT-LAS3.

C. Organization Chart



Notes:

1. Also a qualified operator.
2. Home department is Accelerator Research Department Group A.
3. Home department is Accelerator Research Department Group B.
4. The Accelerator Department Safety Office serves as the Safety Officer in matters of Operational Radiological interest.
5. The EOIC rotation is posted in the control room.